

Our Ref: HL/M100484
Test Report: M104868/A & MA4260/N

7th April 2011

VIP Polymers Ltd.
15 Windover Road,
Huntingdon,
Cambs.
PE29 7EB

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

ETHYLENE PROPYLENE DIENE MONOMER (EPDM) - MATERIAL ONLY

5365

EW54. Black coloured, EPDM sheet material manufactured using transfer moulding. Tested in-radius size 1mm. Shore hardness 55. For use with water up to 23°C.

Note: When processing an application for a Fittings Approval incorporating this product, the in-radius tolerance rule cannot be applied, i.e. the sheet material with a tested in-radius size of 0.5mm is the only product covered by the scope of this approval.


APPROVAL NUMBER: 1012517
APPROVAL HOLDER: VIP POLYMERS LTD.

The Scheme reserves the right to review approval. This approval is valid between December 2010 and December 2015.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully



Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme